

**PRE-QUALIFYING REQUIREMENTS:**

**These pre qualifying requirements (PQR) shall prevail over the pre qualifying conditions mentioned in instructions to tenderer's or anywhere in the tender document.**

1. The tenderer shall meet either of the following pre qualifying conditions for regular bidder:

(a)The tenderer is an established transformer manufacturer satisfying the following three conditions:-

(i)Have supplied within last three years at least 10 nos. 33/11 KV new transformers of 5 MVA or above rating to any Govt. utility directly or through EPC contractor.

(ii)The transformers supplied by the firm are giving satisfactory performance for at – least two year and the damage rate during guarantee period should not be more than 10%. Certificate of satisfactory performance to be enclosed necessarily for each govt. utility or public utility to which the transformers have been supplied.

(iii) The minimum average annual turnover (MAAT) of the firm should not be less than 10.00 Cr. for the best three years out of preceding five financial years. The CA certificate with UDIN number and audited balance sheet shall be enclosed in support of above, failing which the bid may not be considered.

“OR”

(b)The tenderer is repairer of Power Transformers for any Govt.department or Public utility satisfying following three conditions:-

(i)Must have repaired within last three years at least 15 nos.33/11 KV transformers of capacity 5 MVA or above satisfactorily.

(ii)The repaired transformers should have been in satisfactory service for at least two year. The damage rate during guarantee period should not be more than 10%. Certificate of satisfactory performance to be enclosed necessarily for each govt. utility to which the transformers have been supplied.

(iii) The minimum average annual turnover (MAAT) of the firm should not be less than 5.00 Cr. for the best three years out of preceding five financial years. The CA certificate with UDIN number and audited balance sheet shall be enclosed in support of above, failing which the bid may not be considered..

2. The purchaser at his discretion may also consider to award trial order to bidders meeting following conditions:-

(a) The tenderer is an established transformer manufacturer satisfying the following three conditions:-

(i)Have supplied within three years at least 5 nos. new 33/11 KV transformers of 5 MVA or above rating to any Govt. utility directly or through EPC contractor.

(ii)The transformers supplied by the firm are giving satisfactory performance for at-least one year and the damage rate during guarantee period should not be more than 10%. Certificate of satisfactory performance to be enclosed necessarily for each govt. utility to which the transformers have been supplied.

(iii) The minimum average annual turnover (MAAT) of the firm should not be less than 2.50 Cr. for the best three years out of preceding five financial years. The CA certificate with UDIN number and audited balance sheet shall be enclosed in support of above, failing which the bid may not be considered..

OR

(b)The tenderer is repairer of Power Transformers for U.P. Power Corporation Ltd., or any other Govt.department or Public utility satisfying following two conditions:-

- (i) Must have repaired within last three years at least 5 nos. 33/11 KV transformers of capacity 5 MVA or above satisfactorily.
- (ii) The repaired transformers should have been in satisfactory service for at least one year. Certificate of satisfactory performance be enclosed and the damage rate during guarantee period should not more than 10% Certificate of satisfactory performance to be enclosed necessarily from each Govt. utility for which the transformers have been supplied.
- (iii) The minimum average annual turnover (MAAT) of the firm should not be less than 2.50 Cr. for the best three years out of preceding five financial years. The CA certificate with UDIN number and audited balance sheet shall be enclosed in support of above, failing which the bid may not be considered..
- (c) The trial firm may be allotted 10% of the tendered qty. for repair.

**NOTE: The experience of minor repairs against work-order at division level shall not be considered. The repair works must involve manufacturing of HV/LV coils and complete testing of transformer as per clause '16' of Technical Specification.**

## 2. TESTING FACILITIES :

The tenderer must have all necessary facilities at their works for carrying out such routine and acceptance tests as prescribed in the relevant ISS and any other routine and acceptance test as specified in the specification. Documentary evidence of existence of such facilities will be filed alongwith the tender.

## 3. THE DATE CONSIDERATIONS:

The above cited experience and manufactured quantities shall be counted as on the date of opening of the tender. All statements and claims should be duly supported by authenticated copies of documents without which the tender is liable to be rejected summarily.

## 4. GUARANTEE

- 4.1 The repaired transformer shall be guaranteed for the period of 24 calendar months. If the transformer damages during 24 month guarantee period then after re-repair, the performance guarantee shall be for the period remained in 24 months or 6 months whichever is more on the date of damage. The firm shall lift and re-install the re-repaired transformer within a period of 45 days from date of intimation. The joint inspection report (JVR) and stage inspection of the re-repaired transformer shall be carried out.
- 4.1 (a) If the repairer fails to re-install the re-repaired transformer damaged under guarantee period within the specified time then a penalty of (As per form A Condition) at the cost of repair as mentioned in LOI of particular job will be imposed on expiry of 07 days of schedule time for lifting. The date for this shall be counted after seven days from the date of damage intimated to the firm.
- 5 If the repairer fails to lift the transformers damaged under guarantee period, within 15 days from the date of intimation then the same shall be got repaired by other agencies. In such case an amount equal to repair estimate raised by the other repairer for repairing such transformer along with the transportation charges thus incurred by PVVNL shall be recovered from the repairer and the performance BG of the firm shall also be forfeited, the action like debarring /blacklisting against the erring repairer may be initiated.
- 6. **Delivery Period**-(A) Firm has to lift the damage power Transformer within 07 Days from issue of Lifting order by SE (Store), PVVNL, Meerut in normal condition otherwise a penalty of 0.5% per week (As per form A Condition) at the cost of repair as mentioned in LOI of particular job will be imposed on expiry of 07 days of schedule time for lifting.
- (B) within 70 days reckoned from the date of sanction of estimate of job. If the contractor fails to repair the damaged transformer within specified time (70 days Reckoned from date of sanction of estimate of particular job) then a penalty of Rs. 1000.00 per MVA per day shall be deducted from the firm's bill or security (in case of no bill is pending at discom) subject to following maximum amount mentioned as under.

- I. Maximum amount equal to cost of repair of that particular job as per sanction estimate up to time limit of 90 days from date of expiry of schedule delivery.
  - II. Maximum amount equal to cost of New Transformer of similar rating as per stock issue rate after expiry of 90 days from schedule delivery.
7. The price bid of trial firm shall not be opened but the firm has to submit their price bid online so as to complete the e-tendering process. In case of award, the firm may be offered rates as approved by the purchase committee for lowest regular supplier.

**Note: 1- Any Certificate issued by the Chartered Accountant must have Unique Document Identification Number (UDIN) failing which the C.A. certificate may not be considered.**

***All statements and claims regarding turnover, operational and manufacturing experience and production capacity should be duly supported by authenticated copies of documents without which the tender is liable to be rejected summarily. PVVNL may call the tenderer to produce original purchase order/despatch instruction or any other document for verification of submitted documents during the evaluation of their bid. The bidder is also required to submit an affidavit on stamp paper regarding the firm not being blacklisted by any government utility anywhere in India. If any information provided by the bidder is found to be concealed, suppressed or incorrect at the later date, may lead to not only the cancellation of purchase order, if placed by on the tenderer, along with imposition of financial penalty and business debarment.***

***Note: If the firm is qualifying all the prequalifying criteria and participating first time for tendered item or have not supplied similar item in UPPCL, the factory inspection may be carried out for certain parameters as manufacturing/operational experience /production capacity, financial capabilities and certain NOC from competent authority as: for security clearance for fire and accidents and other regulatory requirements. If the firm do not meet out the required criteria for factory inspection, the bid of the firm MAY not be considered for further evaluation.***

***PVVNL reserves the right to waive minor deviation if they do not materially affect the capability of the applicant to perform the contract.***

(Note: The above delivery condition shall supersede any other clause regarding delivery and penalty, if mentioned anywhere else in the terms and condition of tender.