

TECHNICAL SPECIFICATION & GTP

AL” JOINTING SLEEVES FOR USE IN REPAIRING OF DISTRIBUTION TRANSFORMER

Description of Material				
AL” Jointing Sleeves suitable for use in repairing of Distribution Transformer of various capacities, confirming the relevant IS: 8308:1993 with latest amendment.				
<u>size</u> 1. AL” Jointing Sleeves 70mm CIA 2. AL” Jointing Sleeves 150mm CIA 3. AL” Jointing Sleeves 240mm CIA				
<u>Technical Particulars</u>				
Sl no	Particulars	AL” Jointing Sleeves (70mm)	AL” Jointing Sleeves (150mm)	AL” Jointing Sleeves (240mm)
1	Total Length	55mm	71 mm	90 mm
2	Inner Dia	11 mm	16.7 mm	21 mm
3	Outer Dia	15 mm	21.3 mm	28 mm
4	Tolerance	$\pm 5\%$		

Note:-

1. No negative tolerance allowed in length.
2. All specification and Testing should be as per IS: 8303:1993
3. All the Acceptance Test should be carried out as per provision of IS 8303:1993 with Latest Amendment.
4. If facility of any acceptance test of above material is not available at firm’s premises, then inspecting authority will send a sealed sample of the above material to NABL lab for such test and mentioned lot will be accepted only when it successfully pass in acceptance test. The cost of such test (s) shall be borne by the supplier firm.