

**TECHNICAL SPECIFICATION& GTP,**

**MS PIPE VENT (J) TYPE FOR SILICA GEL BREATHER OF DISTRIBUTION TRANSFORMER**

<b>Description of Material</b>		
MS Pipe Vent (J) type for Silica Gel Breather of Distribution Transformers.		
<b><u>Technical Particulars</u></b>		
Sl no	Particulars	Description
1	Material	MS
2	Pipe OD	21 mm
3	Pipe ID	18 mm
4	Pipe Weight	200 gm (approx.)
5	Tolerance	$\pm 3\%$

**Note:-**

1. If facility of any acceptance test of above material is not available at firm's premises, then inspecting authority will send a sealed sample of the above material to NABL lab for such test and mentioned lot will be accepted only when it successfully pass in acceptance test. The cost of such test (s) shall be borne by the supplier firm.