

**MS Plate Size 150x100x2 mm**

Name of Firm :

P.O No :

Rating /G.P : 10 KVA / 60 Months

Unique No :

Date of INSP :

REP(UGP) : / /

- Note: 1. M.S. Plate of size 150x100x2mm shall be continuously welded on same side wall of the T/F, on which Name plate detail has been fixed.
2. Size of letters / digits to be engraved shall be approx 10 mm and depth of engraving shall be approx 0.5 mm.
3. In “REP(UGP) : ...../...../.....,” column, engraving of date of I<sup>st</sup>, II<sup>nd</sup> & III<sup>rd</sup> repair of the T/F in Guarantee period, if any, shall be sequentially done in the blank space by the firm.